

## SIL Declaration

Regarding SIL and PFD (probability of failure on demand) - Monitran Ltd. hereby certifies that our sensor series below comply with IEC 61508-2:2010 to SIL 1 capability (without diagnostics) and SIL 2 capability (with diagnostics). Letter of attestation from CSA with test report R80169395A dated 8<sup>th</sup> August 2023 available on request.

Sensors included in the assessment:

1100, 1100I, 1120, 1185, 1185I, 1186, 1187, 1187I, 2200, 2200I, 2285, 2285I, 2287 and 2287I series.



September 2023  
Christopher Toovey  
Quality Assurance manager  
Monitran Ltd